

Certificate of test

RTF200430 SFC1.0

This is to certify that the product described below was tested by this laboratory at the request of the test sponsor in accordance with AS 1530.1:1994 (R2016).

Test sponsor Rockcote Enterprises Pty Ltd **Address** 18 Machinery Road
Yandina QLD 4561
Australia

Product name Quick Render Quick Float

Test specimen Pre-blended cement render consisting of 20 – 22 % off-white cement, 75 – 80 % silica sand, 1 % mineral additives and < 0.3 % organic additives, as nominated by the test sponsor. The material was off-white in colour and had an as received measured density of 1,510 kg/m³.

Date of test 10 November 2020 **Test report** RTF200430 R1.0

Test standard AS 1530.1:1994 (R2016)

Test results

The material is not deemed combustible according to the test criteria for combustibility specified in clause 3.4 of AS 1530.1:1994 (R2016).

Conditions/validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Please refer to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.
- The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to, and conducted in accordance with our standard terms and conditions. These are available on request or at <https://www.element.com/terms/terms-and-conditions>.

Signed on behalf of Warringtonfire Australia



Muntaqim Pereira
Fire testing engineer

Issue date 18 December 2020